


ADDENDUM NO. 1

**PROJECT NAME:
CONEJO CREEK DOG PARK
PARKING LOT IMPROVEMENT PROJECT**

September 10, 2017

This Addendum form is a part of the Contract Documents for the above-identified project and modifies the original Specifications and Contract Documents, as noted on the following pages. Portions of the Contract, not specifically mentioned in this Addendum, remain in force. All trades affected shall be fully advised of these changes, deletions, and additions.

The bid due date will remain Tuesday, September 26, 2017 at 10:00 a.m.



Andrew Mooney
Park Planner
Conejo Recreation and Park District

BIDDERS CERTIFICATE

I acknowledge receipt of all three (3) pages of this Addendum No. 1 and accept the aforementioned.

Bidders Signature

Date

**THIS DOCUMENT TO BE SIGNED
AND SUBMITTED WITH BID**

**CONEJO CREEK DOG PARK
PARKING LOT IMPROVEMENT PROJECT**

September 10, 2017

ADDENDUM NO. I

The following additions and/or corrections shall become a part of the Contract Documents and Specifications for the above named project. When submitting a bid for the project, this Addendum shall be acknowledged and ***a signed copy of the Addendum shall be included in the bid package.***

Changes or clarifications are noted are BOLD and UNDERLINED

I. GENERAL

The bidder is directed to make the following corrections, deletions, and/or additions to the contract documents and contract drawings heretofore dispensed to him for the above project, and to note bidder's receipt of this addendum by number on the attached ***Addenda Acknowledgement Form***:

II. MODIFICATIONS TO PREVIOUS ADDENDA

N/A

III. BIDDING AND CONTRACT REQUIREMENT REVISIONS

Clarification on Form of Bid – work to be completed in sixty (60) calendar days – see attached revised sheet.

IV. PLAN REVISIONS

Revisions to scope of work regarding waterline alignment see revised Civil Set

Clarification of scope of work regarding fencing see revised Civil Set

V. RFI

Question I: What would be the detail (thickness) of Asphalt and Base (CAB) in the parking lot. Can we use CMB (Crushed miscellaneous Base)?

Answer I: Asphalt to be 3" thick with 10" aggregate base – refer to Civil plans. Base must meet current Greenbook specifications.

Question 2: Do we need to install Manholes instead of clean outs in the sewer line? If yes, please provide detail and the number of MHs.

Answer 2: Refer to Civil plans.

Question 3: Does the restroom building require any electrical, power connection or will it just be run on solar panels? The plans do now show conduit or point of connection for power.

Answer 3: Restroom building is solar powered.

Question 4: Do we have to add any cost of the permit to our bid?

Answer 4: All permits to be paid by Conejo Recreation and Park District.

When submitting a bid for the project, this Addendum shall be acknowledged and a signed copy of the Addendum shall be included in the bid package

FORM OF BID

TO: CONEJO RECREATION AND PARK DISTRICT
403 HILLCREST DRIVE
THOUSAND OAKS, CALIFORNIA 91360

FOR: CONEJO CREEK DOG PARK PARKING LOT IMPROVEMENT PROJECT

Pursuant to, and in compliance with, your Plans and Specifications relating hereto, the undersigned contractor hereby offers to furnish all labor, materials, supplies, equipment and other facilities and things necessary or proper for, or incidental to, the complete construction, including all trades as required by, and in strict accordance with, the applicable provisions of Plans and Specifications entitled:

CONEJO CREEK DOG PARK PARKING LOT IMPROVEMENT PROJECT

and of all addenda issued by the District, for the sum of:

TOTAL BASE BID

	Words
	Figures

In case of discrepancy between the written price and the numerical price, the written price shall prevail.

The undersigned contractor agrees to complete the work in sixty (60) calendar days, which shall be the contract time, commencing ten (10) calendar days after Notice to Proceed is issued to the undersigned contractor.

The undersigned contractor has checked all words and figures inserted in the bid submittal, and understand that the District will make no allowance for any error or omission on the part of the undersigned.

The undersigned contractor recognizes the relations of trust and confidence that will be established between himself and the District by a contract, if awarded to him, and agrees in such event that the Drawings and other Contract Documents shall be deemed to be "instruments of service" and that he will use the documents for the sole purpose of completion of the contract in the best and soundest manner and in the most expeditious and economical way consistent with the interest of the Owner.

The District reserves the right to reject any or all bids, to accept other than the lowest bid, and to waive any irregularity in the bids received. **The award of contract, if made, will be**